



Consulting ■ Engineering ■ Project Management  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531  
Fax: (219) 464-9166

**Asbestos Abatement Summary of Activities**

**Client:** Valparaiso Community Schools  
**Project:** Asbestos Abatement  
Transite Panels Above Windows  
**Project Location:** Cooks Corners Elementary School  
Classrooms EA-123, EA-125, EA-127

**Date Activity Started:** 05/26/2017 **Date Activity Concluded:** 05/26/2017

**Work Performed and Amount of Asbestos Containing Materials Removed**

Description	Each	Square Feet	Linear Feet
Transite Above Windows		48	
<b>Total</b>		<b>48</b>	

**Consultant:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Project Designer:** John Blosky

**License Number:** 190823109 **Expiration Date:** 01/03/2018

**Visual Inspection By:** Juan Gutierrez **Date:** 05/26/2017

**Air Monitoring Firm:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Contractor:** Safe Environment Corporation  
10030 Express Drive  
Highland, IN 46322  
(219) 922-0844

**License Number:** 193721047 **Expiration Date:** 05/17/2018

**Supervisor:** Juan Gutierrez

**License Number:** 19A005442 **Expiration Date:** 02/06/2018

**Laboratory Name:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383

**Analysis Date:** Daily Throughout Project

**Accreditation:** AIHA # (PCM): 100953

**Analyzed By:** Devyn Unger                      Signed: Yes

**Landfill:** Laraway Landfill  
21233 W. Laraway Road  
Joliet, IL 60436  
(815) 727-6148

**Debris Hauled By:** Safe Environmental Corporation  
10030 Express Drive, Suites A & B  
Highland, IN 46322  
(219) 922-0844

**Hauled to Landfill By:** Homewood Disposal Services  
1501 W. 175<sup>th</sup> Street  
Homewood, IL 60430  
(708) 798-1004

**THIS IS A SUMMARY OF ASBESTOS ABATEMENT OR RESPONSE ACTION RECORDS THAT ARE AN INTEGRAL PORTION OF THE MANAGEMENT PLAN OF THIS BUILDING.**

# AMERECO, INC.



Consulting ■ Engineering ■ Project Management  
 54 Michigan Avenue  
 Valparaiso, IN 46383  
 (219) 531-0531  
 Fax: (219) 464-9166

## FIBER CONCENTRATION REPORT

**DATE:** May 26, 2017      **REPORTED TO:** Mr. Todd Van Keppel  
 Valparaiso Community Schools  
**PROJECT:** Cooks Corners Elementary School  
 Valparaiso, IN 46383      55 Evans Avenue  
 Valparaiso, IN 46383  
**PROJECT NO.:** 18.5000.3.10      **ANALYTICAL METHOD:** PCM – NIOSH Method 7400  
 400-450X Magnification

\*\*\*\*\*  
 Following are the analytical results of three (3) clearance air samples collected following the removal of transite panels above windows in classrooms EA-123, EA-125, EA-127 at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

<b>Sample Type:</b>	PER – Personal ** - Excursion	TWA - 8hr. Time Weighted Average	BKG - Background IA - Inside Area OA - Outside Area	CLR - Clearance NEG - Negative Air Exhaust	IAQ - Indoor Air Quality
---------------------	----------------------------------	--	---	--	-----------------------------

<b>Activity:</b>	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out
------------------	-------------------------------------	---------------------------------	--------------

Sample ID	Date Collected	Sample Type/Activity	Location	Fibers/CC
CC-07	05/26/17	CLR	Exterior of Classroom EA-127	<0.01
CC-08	05/26/17	CLR	Exterior of Classroom EA-125	<0.01
CC-09	05/26/17	CLR	Exterior of Classroom EA-123	<0.01

Clearance Level = <0.01 Fibers/CC

Analyzed by: Amereco, Inc.  
 AIHA Laboratory ID No. 100953



**Asbestos Abatement Summary of Activities**

**Client:** Valparaiso Community Schools  
55 Evans Avenue  
Valparaiso, IN 46383

**Project:** Asbestos Abatement  
Transite Panel Above Window

**Project Location:** Room EA-103  
Cooks Corners Elementary School

**Date Activity Started:** 06/16/2017

**Date Activity Concluded:** 06/16/2017

**Work Performed and Amount of Asbestos Containing Materials Removed**

Description	Each	Square Feet	Linear Feet
Transite Panel Above Window		15	
<b>Total</b>		15	

**Consultant:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Project Designer:** John Blosky

**Visual Inspection By:** Hugo Jimenez      **Date:** 06/16/2017

**Air Monitoring Firm:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Contractor:** Safe Environment Corporation  
10030 Express Drive, Suites A&B  
Highland, IN 46322  
(219) 922-0844

**License Number:** 193721047      **Expiration Date:** 05/17/2018

**Supervisor:** Hugo Jimenez

**License Number:** 194005115      **Expiration Date:** 03/18/2018

**Laboratory Name:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383

**Analysis Date:** 06/16/2017

**Accreditation:** AIHA # (PCM): 100953

**Analyzed By:** Devyn Unger                      Signed: Yes

**Landfill:** Laraway Landfill  
21233 W. Laraway Road  
Joliet, IL 60436  
(815) 727-6148

**Debris Hauled By:** Safe Environmental Corporation  
10030 Express Drive, Suites A & B  
Highland, IN 46322  
(219) 922-0844

**Hauled to Landfill By:** Homewood Disposal Services  
1501 W. 175<sup>th</sup> Street  
Homewood, IL 60430  
(708) 798-1004

**THIS IS A SUMMARY OF ASBESTOS ABATEMENT OR RESPONSE ACTION RECORDS THAT ARE AN INTEGRAL PORTION OF THE MANAGEMENT PLAN OF THIS BUILDING.**

# AMERECO, INC.



Consulting ■ Engineering ■ Project Management  
 54 Michigan Avenue  
 Valparaiso, IN 46383  
 (219) 531-0531  
 Fax: (219) 464-9166

## FIBER CONCENTRATION REPORT

**DATE:** June 23, 2017      **REPORTED TO:** Mr. Todd Van Keppel  
**PROJECT:** Room EA-103      Valparaiso Community Schools  
 Cooks Corners Elementary School      55 Evans Avenue  
 Valparaiso, IN 46383

**PROJECT NO.:** 18.5000.3.11      **ANALYTICAL METHOD:** PCM – NIOSH Method 7400  
 400-450X Magnification

\*\*\*\*\*  
 Following are the analytical results of three (3) clearance air samples collected following the removal of the transite panel above the window in room EA-103 at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

<b>Sample Type:</b>	PER – Personal ** - Excursion	TWA - 8hr. Time Weighted Average	BKG - Background IA - Inside Area OA - Outside Area	CLR - Clearance NEG - Negative Air Exhaust	IAQ - Indoor Air Quality O.L. - Overload
---------------------	----------------------------------	--	---	--	---

<b>Activity:</b>	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out
------------------	-------------------------------------	---------------------------------	--------------

Sample ID	Date Collected	Sample Type/Activity	Location	Fibers/CC
CCT-08	06/16/17	CLR	Inside Mini Containment – Outside of EA-103	<0.01
CCT-09	06/16/17	CLR	Room EA-103 – West Side	<0.01
CCT-10	06/16/17	CLR	Room EA-103 – East Side	<0.01

Clearance Level = <0.01 Fibers/CC

Analyzed by: Amereco, Inc.  
 AIHA Laboratory ID No. 100953



**Asbestos Abatement Summary of Activities**

**Client:** Valparaiso Community Schools

**Project:** Asbestos Abatement  
 Transite Panels Above Windows

**Project Location:** Cooks Corners Elementary School  
 Classrooms EA-146, EA-144, EC-102

**Date Activity Started:** 06/24/2017

**Date Activity Concluded:** 06/24/2017

**Work Performed and Amount of Asbestos Containing Materials Removed**

Description	Each	Square Feet	Linear Feet
Transite Above Windows		32	
<b>Total</b>		32	

**Consultant:** Amereco, Inc.  
 54 Michigan Avenue  
 Valparaiso, IN 46383  
 (219) 531-0531

**Project Designer:** John Blosky

**License Number:** 190823109      **Expiration Date:** 01/03/2018

**Visual Inspection By:** Sidney Florida      **Date:** 06/24/2017

**Air Monitoring Firm:** Amereco, Inc.  
 54 Michigan Avenue  
 Valparaiso, IN 46383  
 (219) 531-0531

**Contractor:** Midwest Construction Services  
 9574 N. Industrial Drive  
 Saint John, IN 46373  
 (219) 365-8802

**License Number:** 19A001968      **Expiration Date:** 02/25/2018

**Supervisor:** Sidney Florida

**License Number:** 19A007416      **Expiration Date:** 05/08/2018

**Laboratory Name:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383

**Analysis Date:** Daily Throughout Project

**Accreditation:** AIHA # (PCM): 100953

**Analyzed By:** Aaron Wilker Signed: Yes

**Landfill:** Laraway Landfill  
21233 W. Laraway Road  
Joliet, IL 60436  
(815) 727-6148

**Debris Hauled By:** Midwest Construction Services  
9574 N. Industrial Drive  
Saint John, IN 46373  
(219) 365-8802

**Hauled to Landfill By:** Homewood Disposal Services  
1501 W. 175<sup>th</sup> Street  
Homewood, IL 60430  
(708) 798-1004

**THIS IS A SUMMARY OF ASBESTOS ABATEMENT OR RESPONSE ACTION RECORDS THAT ARE AN INTEGRAL PORTION OF THE MANAGEMENT PLAN OF THIS BUILDING.**



# AMERECO, INC.



Consulting ■ Engineering ■ Project Management  
 54 Michigan Avenue  
 Valparaiso, IN 46383  
 (219) 531-0531  
 Fax: (219) 464-9166

## FIBER CONCENTRATION REPORT

**DATE:** June 24, 2017      **REPORTED TO:** Mr. Todd Van Keppel  
 Valparaiso Community Schools  
**PROJECT:** Cooks Corners Elementary School  
 Valparaiso, IN 46383      55 Evans Avenue  
 Valparaiso, IN 46383  
**PROJECT NO.:** 18.5000.3.12      **ANALYTICAL METHOD:** PCM – NIOSH Method 7400  
 400-450X Magnification

\*\*\*\*\*  
 Following are the analytical results of three (3) clearance air samples collected following the removal of transite panels above windows in classrooms EA-146, EA-144 and EC-102 at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

<b>Sample Type:</b>	PER – Personal ** - Excursion	TWA - 8hr. Time Weighted Average	BKG - Background IA - Inside Area OA - Outside Area	CLR - Clearance NEG - Negative Air Exhaust	IAQ - Indoor Air Quality
---------------------	----------------------------------	--	---	--	-----------------------------

<b>Activity:</b>	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out
------------------	-------------------------------------	---------------------------------	--------------

Sample ID	Date Collected	Sample Type/Activity	Location	Fibers/CC
CC-07	06/24/17	CLR	Classroom EA-146 – East	<0.01
CC-08	06/24/17	CLR	Classroom EA-144 – Center	<0.01
CC-09	06/24/17	CLR	Classroom EC-102 – West	<0.01

Clearance Level = <0.01 Fibers/CC

Analyzed by: Amereco, Inc.  
 AIHA Laboratory ID No. 100953

# AMERECO, INC.



Consulting ■ Engineering ■ Project Management  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531  
Fax: (219) 464-9166

## Asbestos Abatement Summary of Activities

**Client:** Valparaiso Community Schools  
55 Evans Avenue  
Valparaiso, IN 46383

**Project:** Asbestos Abatement  
Transite Paneling Above Windows

**Project Location:** EA-139, EA-141, EA-151, EA-152, EB-101 and EB-106  
Cooks Corners Elementary School

**Date Activity Started:** 06/28/2017

**Date Activity Concluded:** 06/28/2017

### Work Performed and Amount of Asbestos Containing Materials Removed

Description	Each	Square Feet	Linear Feet
Transite Panel Above Window		105	
Cementitious Pipe Insulation			32
<b>Total</b>		<b>105</b>	<b>32</b>

**Consultant:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Project Designer:** John Blosky

**Visual Inspection By:** Hugo Jimenez **Date:** 06/28/2017

**Air Monitoring Firm:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Contractor:** Safe Environmental Corporation  
10030 Express Drive, Suites A&B  
Highland, IN 46322  
(219) 922-0844

**License Number:** 193721047 **Expiration Date:** 05/17/2018

**Supervisor:** Hugo Jimenez

**License Number:** 194005115 **Expiration Date:** 03/18/2018

**Laboratory Name:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383

**Analysis Date:** 06/28/2017

**Accreditation:** AIHA # (PCM): 100953

**Analyzed By:** Devyn Unger                      Signed: Yes

**Landfill:** Laraway Landfill  
21233 W. Laraway Road  
Joliet, IL 60436  
(815) 727-6148

**Debris Hauled By:** Safe Environmental Corporation  
10030 Express Drive, Suites A & B  
Highland, IN 46322  
(219) 922-0844

**Hauled to Landfill By:** Homewood Disposal Services  
1501 W. 175<sup>th</sup> Street  
Homewood, IL 60430  
(708) 798-1004

**THIS IS A SUMMARY OF ASBESTOS ABATEMENT OR RESPONSE ACTION RECORDS THAT ARE AN INTEGRAL PORTION OF THE MANAGEMENT PLAN OF THIS BUILDING.**

# AMERECO, INC.

Consulting ■ Engineering ■ Project Management  
 54 Michigan Avenue  
 Valparaiso, IN 46383  
 (219) 531-0531  
 Fax: (219) 464-9166

## FIBER CONCENTRATION REPORT

**DATE:** July 5, 2017      **REPORTED TO:** Mr. Todd Van Keppel  
**PROJECT:** EA 139, 141, 151, 152, EB 101 and EB 106      Valparaiso Community Schools  
 Cooks Corners Elementary School      55 Evans Avenue  
 Valparaiso, IN 46383

**PROJECT NO.:** 18.5000.3.13      **ANALYTICAL METHOD:** PCM – NIOSH Method 7400  
 400-450X Magnification

\*\*\*\*\*  
 Following are the analytical results of nine (9) clearance air samples collected following the removal of transite panels above windows and cementitious pipe insulation at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

<b>Sample Type:</b>	PER – Personal ** - Excursion	TWA - 8hr. Time Weighted Average	BKG - Background IA - Inside Area OA - Outside Area	CLR - Clearance NEG - Negative Air Exhaust	IAQ - Indoor Air Quality
---------------------	----------------------------------	--	---	--	-----------------------------

<b>Activity:</b>	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out
------------------	-------------------------------------	---------------------------------	--------------

Sample ID	Date Collected	Sample Type/Activity	Location	Fibers/CC
CCW-09	06/28/17	CLR	Outside Library EA-152 – Inside Containment – West Window	<0.01
CCW-10	06/28/17	CLR	Outside Library EA-152 – Inside Containment – East Window	<0.01
CCW-11	06/28/17	CLR	Outside Teachers Prep Room EA-151 – By Window	<0.01
CCW-17	06/28/17	CLR	Outside Classroom EA-139 – Inside Containment	<0.01
CCW-18	06/28/17	CLR	Outside Classroom EA-141 – Inside Containment	<0.01
CCW-19	06/28/17	CLR	Storage Room EB-106 – East Wall	<0.01
CCW-20	06/28/17	CLR	Storage Room EB-106 – Center	<0.01
CCW-21	06/28/17	CLR	Storage Room EB-106 – West Wall	<0.01
CCW-24	06/28/17	CLR	Mechanical Room EB-101 – Inside Containment	<0.01

Clearance Level = <0.01 Fibers/CC

Analyzed by: Amereco, Inc.  
 AIHA Laboratory ID No. 100953



**Asbestos Abatement Summary of Activities**

**Client:** Valparaiso Community Schools

**Project:** Asbestos Abatement

**Project Location:** Cooks Corner Elementary School

**Date Activity Started:** 12/30/2016

**Date Activity Concluded:** 01/03/2017

**Work Performed and Amount of Asbestos Containing Materials Removed**

Description	Each	Square Feet	Linear Feet
Transite Above Windows - EA-111 and EA-113		15	
Gasketing – Boiler Room		2	
<b>Total</b>		<b>17</b>	

**Consultant:** Amereco, Inc.  
204 E. Jefferson Street  
Valparaiso, IN 46383  
(219) 531-0531

**Project Designer:** John Blosky

**License Number:** 190823109      **Expiration Date:** 1/03/2018

**Visual Inspection By:** Carl Fulkerson      **Date:** 01/03/2017

**Air Monitoring Firm:** Amereco, Inc.  
204 E. Jefferson Street  
Valparaiso, IN 46383  
(219) 531-0531

**Contractor:** Midwest Construction Services  
9574 N. Industrial Drive  
Saint John, IN 46373  
(219) 365-8802

**License Number:** 19A001968      **Expiration Date:** 02/25/17

**Supervisor:** Carl Fulkerson

**License Number:** 19A001116      **Expiration Date:** 06/01/17

**Laboratory Name:** Amereco, Inc.  
204 E. Jefferson Street  
Valparaiso, IN 46383

**Analysis Date:** Daily Throughout Project

**Accreditation:** AIHA # (PCM): 100953

**Analyzed By:** Jeff Rugg Signed: Yes

**Landfill:** Laraway Landfill  
21233 W. Laraway Road  
Joliet, IL 60436  
(815) 727-6148

**Hauled to Landfill By:** Homewood Disposal Services  
1501 W. 175<sup>th</sup> Street  
Homewood, IL 60430  
(708) 798-1004

**THIS IS A SUMMARY OF ASBESTOS ABATEMENT OR RESPONSE ACTION RECORDS THAT ARE AN INTEGRAL PORTION OF THE MANAGEMENT PLAN OF THIS BUILDING.**

# AMERECO, INC.



Consulting ■ Engineering ■ Project Management  
 204 E. Jefferson Street  
 Valparaiso, IN 46383  
 (219) 531-0531  
 Fax: (219) 464-0464

## FIBER CONCENTRATION REPORT

**DATE:** January 18, 2017      **REPORTED TO:** Mr. Todd Van Keppel  
 Valparaiso Community Schools  
**PROJECT:** EA-111, EA-113 & Boiler Room  
 Cooks Corners Elementary School      55 Evans Avenue  
 Valparaiso, IN 46383  
**PROJECT NO.:** 18.5000.3.8      **ANALYTICAL METHOD:** PCM – NIOSH Method 7400  
 400-450X Magnification

\*\*\*\*\*  
 Following are the analytical results of eleven (11) clearance air samples collected following the asbestos abatement at the above captioned site. The samples were analyzed by NIOSH Method 7400 using Phase Contrast Microscopy at 400 - 450X magnification. Method 7400 measures the concentration of all fibers present, asbestos and non-asbestos.

<b>Sample Type:</b>	PER – Personal ** - Excursion	TWA - 8hr. Time Weighted Average	BKG - Background IA - Inside Area OA - Outside Area	CLR - Clearance NEG - Negative Air Exhaust	IAQ - Indoor Air Quality
---------------------	----------------------------------	--	---	--	-----------------------------

<b>Activity:</b>	GR - Gross Removal CU - Clean Up	GB - Glovebag PR - Site Prep	BO - Bag Out
------------------	-------------------------------------	---------------------------------	--------------

Sample ID	Date Collected	Sample Type/Activity	Location	Fibers/CC
CC12	12/30/16	CLR/GR	South End Inside Containment	<0.01
CC13	12/30/16	CLR/GR	Center Inside Containment	<0.01
CC14	12/30/16	CLR/GR	North End Inside Containment	<0.01
CC21	01/03/17	CLR/GR	Outside Room EA-113 – In Containment	<0.01
CC22	01/03/17	CLR/GR	Outside Room EA-111 – In Containment	<0.01
CC23	01/03/17	CLR/GR	Room EA-113	<0.01
CC24	01/03/17	CLR/GR	Room EA-111	<0.01
CC25	01/03/17	CLR/GR	Center Inside Containment	<0.01
CC29	01/03/17	CLR/GR	Inside Boiler Room Containment	<0.01
CC30	01/03/17	CLR/GR	Outside Boiler Room Containment on Cabinet	<0.01
--	01/03/17	TWA	Carl Fulkerson S.S. No. xxx-xx-5683	<0.01

Clearance Levels = <0.01 Fibers/CC

Analyzed by: Amereco, Inc.  
 AIHA Laboratory ID No. 100953

# AMERECO, INC.

Consulting ■ Engineering ■ Project Management  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531  
Fax: (219) 484-9168

## Asbestos Abatement Summary of Activities

**Client:** Valparaiso Community Schools  
**Project:** Asbestos Abatement  
**Project Location:** Cooks Corners Elementary School  
Kindergarten and Associated Hallway

**Date Activity Started:** 3/31/2017

**Date Activity Concluded:** 04/03/2017

### Work Performed and Amount of Asbestos Containing Materials Removed

Description	Each	Square Feet	Linear Feet
Floor Tile and Associated Black Mastic on Concrete		350	
Sheet-Flooring on Concrete		400	
<b>Total</b>		<b>750</b>	

**Consultant:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Project Designer:** John Blosky

**License Number:** 190823109      **Expiration Date:** 1/03/2018

**Visual Inspection By:** Carl Fulkerson      **Date:** 04/03/2017

**Air Monitoring Firm:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Contractor:** Midwest Construction Services  
9574 N. Industrial Drive  
Saint John, IN 46373  
(219) 365-8802

**License Number:** 19A001968      **Expiration Date:** 02/25/18

**Supervisor:** Carl Fulkerson

**License Number:** 19A001116      **Expiration Date:** 06/01/17



**Laboratory Name:** Amereco, Inc.  
54 Michigan Avenue  
Valparaiso, IN 46383  
(219) 531-0531

**Analysis Date:** Daily Throughout Project

**Accreditation:** AIHA # (PCM): 100953

**Analyzed By:** Devyn Unger                      Signed: Yes

**Landfill:** Laraway Landfill  
21233 W. Laraway Road  
Joliet, IL 60436  
(815) 727-6148

**Hauled to Landfill By:** Homewood Disposal Services  
1501 W. 175<sup>th</sup> Street  
Homewood, IL 60430  
(708) 798-1004

**THIS IS A SUMMARY OF ASBESTOS ABATEMENT OR RESPONSE ACTION RECORDS THAT ARE AN INTEGRAL PORTION OF THE MANAGEMENT PLAN OF THIS BUILDING.**

